

Evaluation Table

PEP ID:	XXXXXX
Manufacturer:	Name of Manufacturer
Product Name:	Name of Product

732 Electrical Underground Material
 732 Metal Junction Box
 ADOT Standard Specification: 732-2.04
 Responsible Section: Traffic Group

Material Property	Specification/ Test Method	Requirement	Results	Pass/ Fail
Fabrication	732-2.04	Metal junction boxes and covers for installation in concrete structures shall be fabricated from a minimum of 16 gage type 304 stainless steel.		
Welding	732-2.04	All seams shall be continuously welded		
Gasket	732-2.04	A neoprene gasket with a thickness of 1/8 inch shall fit between the box and the cover.		
Cover / Hardware	732-2.04	The cover shall be made to fit securely and shall be held in place with a minimum of four stainless steel machine screws.		