



DOWEL DETAIL

GENERAL NOTES

- 1. Backfill shall be in accordance with Section 501 bedding and pipe backfill requirements of the Standard Specifications.
- 2. Aggregate Base shall be in accordance with Section 303 requirements of the Standard Specifications.
- 3. Asphalt concrete shall be in accordance with Section 409 requirements of the Standard Specifications.
- 4. Portland Cement Concrete Pavement shall be in accordance with Section 401 requirements of the Standard Specifications. Match existing surface texture and grade.
- 5. See Std Dwg C-13.15 for pipe culvert installation.
- Replace 2 ft of AC on each side of the excavation along centerline unless otherwise directed by the Engineer. Replace full lane width of all disturbed lanes perpendicular to centerline.
- ▲ All disturbed slabs shall be replaced in full and doweled into adjacent PCCP on each side. See Dowel Detail.
- Use when shown on plans or as directed by the Engineer when minimum cover cannot be attained. See plans for protective slab thickness and reinforcement requirements.
- ♦ A thicker pavement section may be required if shown on plans or directed by the Engineer.



BACKFILL



AGGREGATE BASE

DRAWING NO.

C-07.06

