



FLUORESCENT SIGN LIGHTING

FLUORESCENT LIGHTING FIXTURE LOCATIONS

	Sign Width (Feet)																												
	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29					
NUMBER OF FIXTURES	1	1	1	1	2	2	2	2	2	2	2	2	3	3	3	3	3	3	4	4	4	4	4	4					
"X"(inches)	36	42	48	54	24	30	36	40	44	48	52	56	36	39	42	45	48	51	36	39	40 $\frac{1}{2}$	42	45	46 $\frac{1}{2}$					
"Y"(inches)	0	0	0	0	72	72	72	76	80	84	88	92	72	75	78	81	84	87	72	74	77	80	82	85					

NOTES:

1. All materials and construction shall conform to the requirements of the Specifications.
2. When sign panels are placed side by side so that the sum of their lengths is less than 29' 0"; locate the lighting fixtures using the sum of the sign panel lengths.
3. All fluorescent lighting fixtures shall be 6' in length with 2 lamps and 2 ballasts per fixture (see the Specifications).
4. Locations of fluorescent lighting fixtures typical for overhead mounting.

DESIGN APPROVED <i>Charlie Bauer</i> 7/24/85	STATE OF ARIZONA DEPARTMENT OF TRANSPORTATION DIVISION OF HIGHWAYS STANDARD DRAWINGS	REV.
APPROVED FOR DISTRIBUTION <i>[Signature]</i>	PLACEMENT OF LIGHTING FIXTURES FOR OVERHEAD SIGNS	DRAWING NO. T.S. 13-3