



NOTES:

1. For construction requirements see Specifications.
2. Material - 14 ga. galvanized steel.
3. Control enclosure shall be rainproof and dustproof.
4. For Cabinet Lock Detail see T.S. 3-10.
5. For painting see Specifications.
6. Typical installation of Pan and Jack-In Components, see T.S. 3-15.
7. 3/4" Hub with Internal, Standard Pipe Thread.
8. Use 1 1/2" Tee Vent on large Type I Cabinets only (T.S. 3-1-2).
9. Neoprene Sponge Gasket, 1/4" x 1/2".

TABLE OF DIMENSIONS

Dim.	T.S. 3-1-1 120 - 240	T.S. 3-1-2 240 - 480
A	20"	24"
B	6"	6"
C	12"	20"
D	18"	22"
E	10"	18"

DESIGN APPROVED <i>Charles Brown</i> 7-24-65	STATE OF ARIZONA DEPARTMENT OF TRANSPORTATION DIVISION OF HIGHWAYS STANDARD DRAWINGS	REV
APPROVED FOR DISTRIBUTION	TYPE I LOAD CENTER CABINET	DRAWING NO. T.S. 3-1