



NOTES:

1. All service conductors and service switches shall be 125 Amp. capacity.
2. All components on 240/480 volt circuits shall be rated for 600 volts operation. All other components shall be rated for 250 volts operation.
3. See T.S.3-15 for details on Pan and Jack Mounted Components.
4. See T.S.3-6 for Type IV Load Center Cabinet and Foundation Details.
5. All components shall be interior mounted.
6. The contractor shall consult the Utility Co. concerned to establish and install the proper ampere interruption capacity breakers for each individual installation.
7. All live electrical components shall be protected by a dead-front panel which conforms to the NEC, see specifications.

DESIGN APPROVED <i>Charlie Brown</i> 7/24/65	STATE OF ARIZONA DEPARTMENT OF TRANSPORTATION DIVISION OF HIGHWAYS STANDARD DRAWINGS	REV.
APPROVED FOR DISTRIBUTION	TYPE IV LOAD CENTER CABINET CIRCUIT DETAILS	DRAWING NO T.S. 3-7